

# Compliance Statement

No. 2023-345

## Screened Channel, Class E<sub>A</sub>

### Company

SOCAMONT Industries  
ZI des Touches  
9 rue des frères Lumière  
53000 LAVAL  
France

### Channel Identification (3 connector model)

#### Horizontal cable:

Platine Réseaux Câble Cat6<sub>A</sub> FFTP LSOH 4 Paires 10 GBit 100ohms AWG23 - PN:6710  
Platine Réseaux Câble Cat6<sub>A</sub> FFTP LSOH 2x4 Paires 10 GBit 100 ohms AWG23 - PN:6711

#### RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

Platine Réseaux Jack COCCINELLE RJ45 Cat6<sub>A</sub> FTP 10GIGA - PN:71009

#### Terminal cord, patch cord, equipment cord:

Cordon RJ45 Cat6<sub>A</sub> SFTP 100 ohms LSOH - PN:2215

#### Including use with:

Wall outlet: Platine Réseaux Plastron 1 entrée inclinée DIM 45 X 45 une entrée - PN:71227  
Patch Panel: Platine Réseaux Panneau non équipé 24 ports FTP à accroche Keystone 1U - PN:71007

#### Generic cabling standards - Class E<sub>A</sub> Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

#### Technical report

12323512-01, DANAK-19/23470

#### EC Cabling product ID


5371

#### CS valid until

1 June 2024

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 8 June 2023



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department

