Compliance Statement

No. 2026-721

Screened Channel, Class E_A

Company
SOCAMONT Industries
ZI des Touches
9 rue des frères Lumiére
53000 LAVAL
France

Channel Identification (3 connector model)

Horizontal cable and Consolidation Point cable:
SOCAMONT Câble $Cat6_A$ FFTP LS0H 4 Paires 10 GBit 100ohms AWG23 - PN:6710
SOCAMONT Câble Cat6A FFTP LS0H 2x4 Paires 10 GBit 100 ohms AWG23 - PN:6711

RJ45 connector for Telecommunications Outlet, Consolidation Point, and patch panel:
SOCAMONT Jack COCCINELLE RJ45 $Cat6_A$ FTP 10GIGA - PN:71009

Terminal cord, equipment cord:
Cordon RJ45 Cat6A SFTP 100 ohms LSOH - PN:2215

Including use with:
Wall outlet: SOCAMONT Plastron 1 entrée inclinée DIM 45 X 45 une entrée - PN:71227
Patch Panel: SOCAMONT Panneau non équipé 24 ports FTP à accroche Keystone 1U - PN:71007

Generic cabling standards - Class E_A Channel requirements
- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-E:2024

Technical report	**EC Cabling product ID**	**CS valid until**
12623777-01, DANAK-19/25785	5371	1 June 2027

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 12 May 2026

Nis Jepsen
Specialist, Project Manager

Lars Lindskov Pedersen
Senior Team Leader, Test Manager

FORCE Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
lan.forcetechnology.com